



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEx UL 22.0050X** Page 1 of 3 [Certificate history:](#)

Status: **Current** Issue No: 0

Date of Issue: 2022-08-30

Applicant: **M2I Corporation**
11-35 Simin-daero
327beon-gil Dongan-gu Anyang-si,
Gyeonggi-do, 14055
Korea, Republic of

Equipment: **Industrial HMI Touch Panel, Models TOPRX1200XD-Ex, TOPRX1200SD-Ex, TOPRX1500XD-Ex, TOPRX1000SD-Ex, TOPRX1000VD-Ex.**

Optional accessory:

Type of Protection: **Increased Safety "ec", Intrinsic Safety "ic"**

Marking: **Ex ic ec IIC T6 Gc**
-10°C ≤ Ta ≤ +50°C

Approved for issue on behalf of the IECEx
Certification Body:

Katy A. Holdredge

Position:

Senior Staff Engineer

Signature:
(for printed version)

Date:
(for printed version)

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

UL LLC
333 Pfingsten Road
Northbrook IL 60062-2096
United States of America





IECEx Certificate of Conformity

Certificate No.: **IECEx UL 22.0050X**

Page 2 of 3

Date of issue: 2022-08-30

Issue No: 0

Manufacturer: **M2I Corporation**
11-35 Simin-daero
327beon-gil Dongan-gu Anyang-si,
Gyeonggi-do, 14055
Korea, Republic of

Manufacturing
locations: **M2I Corporation**
11-35 Simin-daero
327beon-gil Dongan-gu Anyang-si,
Gyeonggi-do, 14055
Korea, Republic of

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

IEC 60079-11:2011 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
Edition:6.0

IEC 60079-7:2017 Explosive atmospheres - Part 7: Equipment protection by increased safety "e"
Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[US/UL/ExTR22.0054/00](#)

Quality Assessment Report:

[US/UL/QAR22.0008/00](#)



IECEx Certificate of Conformity

Certificate No.: **IECEx UL 22.0050X**

Page 3 of 3

Date of issue: 2022-08-30

Issue No: 0

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

These industrial HMI touch panels are industrial control devices used in industrial field. They are devices based on RS 232C and RS 422/485, Ethernet which is used for the basic purpose of communication with another device (like a PLC, other industrial control device) incorporating Resistive-touch screen.

All models are similar construction except for LCD/Enclosure size including LCD bracket, Main board and Power Board LCD connection location and Backlight connections.

Please see Annex for additional information.

SPECIFIC CONDITIONS OF USE: YES as shown below:

- The equipment shall only be used in an area of at least pollution degree 2, as defined in IEC 60664-1.
- Equipment shall be installed in a back enclosure with tool removable door or cover that provides a degree of protection not less than IP 54 in accordance with IEC 60079-0.
- Provisions shall be made to prevent the rated voltage from being exceeded by transient disturbances of more than 140%.
- The equipment shall only be installed in locations where there is a low risk of mechanical damage.
- Touch the device after contacting antistatic pad or wearing earth ring to avoid the electrostatic charges.

Annex:

[Annex to IECEx UL 22.0050X Issue 0.pdf](#)